



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

RICHARD K. ELLIS
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM #2

Date: 9 August 2006

To: Contractors

From: Wayne Smith, Project Manager, DFCM

Reference: Governors Mansion HVAC Upgrade
603 East South Temple, SLC Utah
DFCM Project No. 06183310

Subject: **Addendum No. 2**

Pages	Addendum Cover	1	page
	Architects Clarification to Specs	1	page
	Total	2	pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

2.1 SCHEDULE CHANGES – No project schedule changes with this addendum.

2.1.1 GENERAL – WHW Engineering Inc., Clarifications to Specifications & Clarifications to Drawings

End of Addendum #2

ADDENDUM

Project Name: Governor's Mansion HVAC Replacement

Addendum No.: 2

DFCM Project # 06183310

Date: 08-09-06

From: WHW Engineering Inc
1354 East 3300 South Suite 200
Salt Lake City, Utah 84106
Phone (801) 466-4021 Fax (801) 466-8536

To: All bidders

This Addendum forms and becomes a part of the Contract Documents and modifies the original Bidding Documents dated 07-28-06 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page.

I - CHANGES TO PRIOR ADDENDA: None

II - CHANGES TO BIDDING REQUIREMENTS: None

III - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: None

IV – CHANGES/CLARIFICATIONS TO CONDITIONS OF THE CONTRACT: None

V - CHANGES/CLARIFICATIONS TO SPECIFICATIONS:

Item V-1. Specification Section 09912 – 1.4.B.: Add the following 3rd approved painter:
“3. Dave Horn Painting – office: 943-8839, cell: 550-7825”

VI - CHANGES/CLARIFICATIONS TO DRAWINGS:

Item VI-1. Sheet ME101, note 1: revise to read as follows:

“Provide new supply duct from fan coil FC-1. Balance diffusers to cfm shown. If fan coil unit is replaced as part of additive alternate #2, balance diffusers to 1100 cfm each instead of 1000 cfm each.”

Item VI-2. Sheet ME101, note 2: revise to read as follows:

“Provide new supply duct from fan coil FC-5. Balance diffusers to cfm shown. If fan coil unit is replaced as part of additive alternate #1, balance diffusers to 1100 cfm each instead of 800 cfm each.”